



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
RENEWAL of NO OBJECTION CERTIFICATE**



Ack. No.: 205980002019 Issue Date : 30/10/2019

NOC: 00011768/RENEWAL/Rangareddy/2021



NOC TYPE: RENEWAL*

Valid Upto: 29-10-2024

Applicant Details: Mrs.Vasanthy Parasuraman C/o Maharishi Vidya Mandir, Survey No.58/Part Girish Park, Hitech-city Kondapur Rangareddy District.

Building for which NOC issued: Maharishi Vidya Mandir, Survey No.58/Part Girish Park, Hitech-city Kondapur Rangareddy District.

Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening: No

Plot Area (Sq. Mtrs): 2481.00 Height (Metres): 15.00

Open Spaces (Metres): North: (F) 6.00 South: 6.00 East: 10.00 West: 6.00

No. of Floors: 0 Cellars, 0 Stilts, 1 Ground, 3 Floors, 0 Terrace Occupancy Type: EDUCATIONAL B-1 Schools up to senior secondary level

Total Built-up Area (Sq.Mtrs):	1449.20	Staircases:	No. of Staircases Required/Proposed:	2
Fees Paid (₹):	47500		Aggregate Width Required/Proposed (Metres):	3.00


Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:

Fire Extinguisher:	21	First Aid Hose Reel:	4	Wet Riser:	0
Down Comer:	0	Yard Hydrant:	0	Automatic Sprinkler System:	0
Manually Operated Electronic Fire Alarm Systems:	0	Terrace Tank (Litres):	10000		
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	0		


PRINCIPAL
MAHARISHI VIDYA MANDIR
Girish Park, Kondapur,
R. R. Dist. Hyd-500 084.

Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Terrace Level	Type	Quantity	(Capacity in Litres/min)
	Electrical	0	0
	Diesel	0	0
	Jockey	0	0
Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm ²	(Capacity in Litres/min) 900		

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"
** For details and conditions of Renewal No Objection Certificate for Occupancy, refer overleaf.




The Renewal No Objection Certificate for Occupancy is issued subject to following conditions:

- On the basis of the recommendations of the building inspection committee, this Renewal No Objection Certificate for Occupancy is issued.
- Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.
- The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During the inspection, if any violation of No Objection Certificate for Occupancy conditions/non-functioning of fire safety systems is noticed, prosecution will be launched on the Owner/Occupier as per the provisions of Fire Service Act, 1999.
- It is the responsibility of the builder/management to apply for Renewal No Objection Certificate for Occupancy duly remitting the user charges as per G.O.Ms.No.71, (Home Prisons-A) Dep., dated: 01-04-2010, two months before expiry of this No Objection Certificate.

f) The floor wise built-up areas of the building are as follows:

FloorType	BuildUpArea
Ground	362.30
1st Floor	362.30
2nd Floor	362.30
3rd Floor	362.30
Total	1449.20


PRINCIPAL
MAHARISHI VIDYA MANDIR
Girish Park, Kondapur,
R. R. Dist. Hyd-500 084.